

OBSERVATIONS: P0290

Please notice the good corrosion index rate (2.8764 MPY)* of the copper coupon placed in the RY-555 treated water at the municipal water plant effluent to the water distribution matrix.

OBSERVATIONS: P0289

Please notice the good corrosion index rate (2.5903 MPY)* of the copper coupon placed in the All Clear treated water at the well #6 effluent to the water distribution matrix.

***FMC Corrosion Rate Standards: Copper**

5.0 MPY Fair
3.0 MPY Good
2.0 MPY Excellent